

	Guarantee Inlet Temperature=	test2PERCALC.XLS	657	Enthalpy of Liquid	19.46
43	Exit gas temp corrected for guarantee inlet temperature		298.53	Enth of vap@ 1psia	1195.0165
44	Corrected heat loss due to dry gas (percentage)=		5.24		
45	Corrected heat loss due to moisture in fuel (percentage)		0.89		
46	Corrected heat loss due to moist. from comb of H2(%)=		4.04		
47	Corrected Efficiency (percentage)=		88.97		